

Danfoss KVQ/EKC 367			
Control set point	---	-3	-4
Start/Stop of refrigeration	r12	On	On
Actuator max. temperature	n01	130	130
Actuator min. temperature	n02	70	70
Actuator type	n03	5	5
P: Amplification factor Kp	n04	3	3
I: Integration Time Tn	n05	240	240
D: Differentiation time Td	n06	20	20
Transient phenomenon	n07	2	2

Danfoss KVS/EKC 368			
Control set point	---	-3	-4
Start/Stop of refrigeration	r12	On	On
Actuator type	n03	3	3
P: Amplification factor Kp	n04	3	3
I: Integration Time Tn	n05	240	240
D: Differentiation time Td	n06	20	20
Transient phenomenon	n07	2	2